

BOC Kooragang Cooling Tower Wastewater Sampling Report - August 2016

BOC Limited Kooragang Island

26 August 2016



BOC Kooragang Cooling Tower Wastewater Sampling Report - August 2016

BOC Limited Kooragang Island

26 August 2016

MJM Environmental Pty Ltd
 ABN 21 089 600 019
 Office 1, Level 2
 355 Wharf Road
 Newcastle, NSW, 2300
 Telephone: 02 4926 4222
 Facsimile: 02 4929 4944
 E-mail: enquiries@mjmenvironmental.com.au

Document Control				Approved for Issue		
Project No.	Rev	Author	Reviewer	Name	Signature	Date
034-1612	0	A Bucior	B Kelly	B Kelly		26/08/2016

© MJM Environmental 2016

This document shall remain the property of MJM Environmental. Unauthorised use of this document in any form is prohibited. Information contained within this Document is 'Commercial in Confidence'.

Table of Contents

1	INTRODUCTION	4
2	SITE IDENTIFICATION	4
3	SAMPLING PLAN AND METHODOLOGY.....	5
3.1	SAMPLING HANDLING PROCEDURES	5
4	RESULTS.....	6
5	DISCUSSION.....	8

List of Figures

Figure 2-1: BOC Limited Kooragang Vicinity.....	4
Figure 2-2: Location of BOC Limited's Cooling Towers and Wastewater Tanks	5

List of Tables

Table 3-1: Cooling Tower Wastewater Sampling Analytes.....	5
Table 4-1: BOC Limited Cooling Tower Wastewater Sampling Results.....	6

Appendices

- Appendix A – NATA Laboratory Results
- Appendix B – Sampling Field Notes

1 Introduction

BOC Limited Kooragang Island, herein referred to as BOC Kooragang, owns and operates a gas facility for the production and supply of gas products located at 9 Egret Street Kooragang, New South Wales. The facility operates 24 hours per day, 7 days per week. BOC Kooragang holds NSW Environmental Protection Authority (EPA) Environmental Protection Licence (EPL) 20165. The Scheduled Activities in the EPL include chemical storage waste generation, dangerous goods production and general chemicals storage.

BOC Kooragang currently possess two (2) cooling towers onsite. Currently the cooling tower blowdown (waste) water continues to two (2) 10,000 litre capacity storage tanks onsite, totalling a capacity of 20,000 litres storage onsite. The wastewater is collected by an approved waste contractor approximately once per week.

BOC Kooragang are researching the possibility of utilising the cooling tower wastewater for irrigation purposes in specific grassed areas of the site. In order to research the possibility of utilising the cooling tower wastewater onsite MJM Environmental (MJM) was engaged by BOC Kooragang in August 2016 to undertake water sampling and analysis.

This report outlines the results of the wastewater sampling carried out in August 2016.

2 Site Identification

BOC Kooragang operates a gas facility located at 9 Egret Street Kooragang, New South Wales. The plant vicinity map and location of the cooling towers and wastewater storage tanks are shown in Figure 2-1 and Figure 2-2.



Figure 2-1: BOC Limited Kooragang Vicinity



Figure 2-2: Location of BOC Limited’s Cooling Towers and Wastewater Tanks

3 Sampling Plan and Methodology

The analytes tested are presented in Table 3-1, which are taken from the Australian and New Zealand Environment and Conservation Council (ANZECC) 2000 guidelines. The water sampling analysis results were compared to the ANZECC guidelines presented in *Section 4: Primary Industries - 4.2 Water Quality for irrigation and general water use*.

Table 3-1: Cooling Tower Wastewater Sampling Analytes

Analytes		
pH	Herbicides	Iron
Enterococci	Pesticides	Lead
Faecal (thermotolerant) Coliforms	Cadmium	Lithium
Electrical conductivity	Zinc	Manganese
Sodium Absorption Ratio (sodicity)	Aluminium	Mercury
Alkalinity as calcium carbonate (hardness)	Arsenic	Molybdenum
Chloride	Beryllium	Nickel
Sodium	Boron	Selenium
Fluoride	Chromium VI	Uranium
Nitrogen (total)	Cobalt	Vanadium
Phosphorus	Copper	

3.1 Sampling Handling Procedures

Sampling was performed in accordance with ANZECC monitoring standards (AS/NZS 5667.1:1998 and AS/NZS 5667.11:1998). These procedures include the documentation of the name and location of the sample point, date and time of sample collection, the type of sample point, method of sample collection and sample appearance at the time of collection. The water samples were then transferred into clean plastic bottles provided by a NATA accredited laboratory. The NATA laboratory results are presented in Appendix A and field notes in Appendix B.

4 Results

The results for the cooling tower wastewater sampling performed on 18 August 2016 are presented in Table 4-1 below.

Table 4-1: BOC Limited cooling tower wastewater sampling results 18 August 2016

Analyte	Units	Result	Recommended Irrigation Thresholds ¹
pH	pH Unit	8.18	6 – 9
Enterococci	CFU/100mL	~4	-
Faecal (thermo tolerant) Coliforms	CFU/100mL	~1	<10,000 ⁴
Electrical conductivity	µS/cm	1,550	-
Sodium Absorption Ratio	-	4.08	-
Alkalinity as calcium carbonate (hardness)	mg/L	97	-
Chloride	mg/L	307	-
Sodium	mg/L	177	-
Fluoride	mg/L	3.5	1.0 ² 2.0 ³
Nitrogen (total)	mg/L	3.8	25 - 125 ² 5 ³
Phosphorus	mg/L	2.13	0.8 - 12 ² 0.05 ³
Cadmium	mg/L	<0.0001	0.01 ² 0.05 ³
Zinc	mg/L	0.012	2.0 ² 5.0 ³
Aluminium	mg/L	0.12	5.0 ² 20 ³
Arsenic	mg/L	0.002	0.1 ² 2.0 ³
Beryllium	mg/L	<0.001	0.1 ² 0.5 ³
Boron	mg/L	0.18	0.5 ² 2 – 4 ⁵
Chromium VI	mg/L	<0.01	0.1 ² 1.0 ³
Cobalt	mg/L	<0.001	0.05 ² 0.1 ³
Copper	mg/L	0.120	0.2 ² 5.0 ³
Iron	mg/L	0.15	0.2 ² 10 ³
Lead	mg/L	<0.001	2.0 ² 5.0 ³
Lithium	mg/L	0.005	2.5 ² 2.5 ³
Manganese	mg/L	0.003	0.2 ² 10 ³
Mercury	mg/L	<0.0001	0.002 ² 0.002 ³
Molybdenum	mg/L	<0.001	0.01 ² 0.05 ³

Analyte	Units	Result	Recommended Irrigation Thresholds ¹
Nickel	mg/L	0.012	0.2 ² 2.0 ³
Selenium	mg/L	<0.01	0.02 ² 0.05 ³
Uranium	mg/L	<0.001	0.01 ² 0.1 ³
Vanadium	mg/L	<0.01	0.1 ² 0.5 ³
Phenoxyacetic Acid Herbicides			
4-Chlorophenoxy acetic acid	µg/L	<10	1,000 ⁶
2.4-DB	µg/L	<10	1,000
Dicamba	µg/L	<10	1,000
Mecoprop	µg/L	<10	1,000
MCPA	µg/L	<10	1,000
2.4-DP	µg/L	<10	1,000
2.4-D	µg/L	<10	1,000
Triclopyr	µg/L	<10	1,000
2.4.5-TP (Silvex)	µg/L	<10	1,000
2.4.5-T	µg/L	<10	1,000
MCPB	µg/L	<10	1,000
Picloram	µg/L	<10	1,000
Clopyralid	µg/L	<10	1,000
Fluroxypyr	µg/L	<10	1,000
2.6-D	µg/L	<10	1,000
2.4.6-T	µg/L	<10	1,000
Organochlorine Pesticides			
alpha-BHC	µg/L	<0.5	1,000 ⁶
Hexachlorobenzene (HCB)	µg/L	<0.5	1,000
beta-BHC	µg/L	<0.5	1,000
gamma-BHC	µg/L	<0.5	1,000
delta-BHC	µg/L	<0.5	1,000
Heptachlor	µg/L	<0.5	1,000
Aldrin	µg/L	<0.5	1,000
Heptachlor epoxide	µg/L	<0.5	1,000
trans-Chlordane	µg/L	<0.5	1,000
alpha-Endosulfan	µg/L	<0.5	1,000
cis-Chlordane	µg/L	<0.5	1,000
Dieldrin	µg/L	<0.5	1,000
4.4-DDE	µg/L	<0.5	1,000
Endrin	µg/L	<0.5	1,000
beta-Endosulfan	µg/L	<0.5	1,000
4.4-DDD	µg/L	<0.5	1,000
Endrin aldehyde	µg/L	<0.5	1,000
Endosulfan sulfate	µg/L	<0.5	1,000
4.4'-DDT	µg/L	<2.0	1,000
Endrin ketone	µg/L	<0.5	1,000
Methoxychlor	µg/L	<2.0	1,000
Organophosphorus Pesticides			
Dichlorvos	µg/L	<0.5	1,000
Demeton-S-methyl	µg/L	<0.5	1,000
Monocrotophos	µg/L	<2.0	1,000
Dimethoate	µg/L	<0.5	1,000
Diazinon	µg/L	<0.5	1,000
Chlorpyrifos-methyl	µg/L	<0.5	1,000
Parathion-methyl	µg/L	<2.0	1,000
Malathion	µg/L	<0.5	1,000
Fenthion	µg/L	<0.5	1,000
Chlorpyrifos	µg/L	<0.5	1,000
Parathion	µg/L	<2.0	1,000
Pirimphos-ethyl	µg/L	<0.5	1,000

Analyte	Units	Result	Recommended Irrigation Thresholds ¹
Chlorfenvinphos	µg/L	<0.5	1,000
Bromophos-ethyl	µg/L	<0.5	1,000
Fenamiphos	µg/L	<0.5	1,000
Prothiofos	µg/L	<0.5	1,000
Ethion	µg/L	<0.5	1,000
Carbophenothion	µg/L	<0.5	1,000
Azinphos Methyl	µg/L	<0.5	1,000

¹ Australian and New Zealand Environment and Conservation Council (ANZECC) 2000 guidelines - Section 4: Primary Industries - 4.2 Water Quality for irrigation and general water use.

² Short-term trigger value (STV) – The STV is the maximum concentration (mg/L) of contaminant in the irrigation water which can be tolerated for a shorter period of time (20 years).

³ Long-term trigger value (LTV) – The LTV is the maximum concentration (mg/L) of contaminant in the irrigation water which can be tolerated assuming 100 years of irrigation.

⁴ Trigger value chosen for areas with restricted public access.

⁵ Trigger value chosen for moderately tolerant crops.

⁶ General limit set for herbicides for NSW.

5 Discussion

MJM Environmental was engaged by BOC Kooragang to investigate the possibility of utilising the cooling tower wastewater stored onsite for irrigation purposes by undertaking wastewater sampling and analysis. The results were compared to the Australian and New Zealand Environment and Conservation Council (ANZECC) 2000 guidelines. The results for the wastewater samples taken on 18 August 2016 are presented above.

The Short-term Trigger Values (STV) and Long-term Trigger Values (LTV) presented in Table 4-1 are recommendations from the ANZECC guidelines.

From Table 4-1 it can be seen that Fluoride exceeded the STV and LTV with a concentration of 3.5 mg/L. It is noted that the guidelines state *'the LTV has been set on the assumption that irrigation water could potentially be phytotoxic to sensitive plant or contaminate stock drinking water'*.

Phosphorus concentration exceeded the LTV with a concentration of 2.13 mg/L. However it is noted that the guidelines state the LTV for phosphorus is set *'to minimise bioclogging of irrigation equipment only'*.

Pesticides and herbicides were not detected.

The remaining analytes were compliant with the recommended threshold levels.

Appendix A – NATA Laboratory Results

CERTIFICATE OF ANALYSIS

Work Order : ES1618232 Client : MJM ENVIRONMENTAL PTY LTD Contact : MS BRIGID KELLY Address : OFFICE 1, 335 WHARF ROAD NEWCASTLE NSW, AUSTRALIA 2300 Telephone : +61 49264222 Project : 034 1612 Order number : 49264222 C-O-C number : ---- Sampler : ADAM BUCIOR Site : ---- Quote number : ---- No. of samples received : 1 No. of samples analysed : 1	Page : 1 of 7 Laboratory : Environmental Division Sydney Contact : Address : 277-289 Woodpark Road Smithfield NSW Australia 2164 Telephone : +61-2-8784 8555 Date Samples Received : 18-Aug-2016 11:49 Date Analysis Commenced : 18-Aug-2016 Issue Date : 25-Aug-2016 09:38
--	--



This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results
- Surrogate Control Limits

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QA/QC Compliance Assessment to assist with Quality Review and Sample Receipt Notification.

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is carried out in compliance with procedures specified in 21 CFR Part 11.

<i>Signatories</i>	<i>Position</i>	<i>Accreditation Category</i>
Aaron Ivory	Technical Officer	Chemistry, Newcastle West, NSW
Ankit Joshi	Inorganic Chemist	Sydney Inorganics, Smithfield, NSW
Celine Conceicao	Senior Spectroscopist	Sydney Inorganics, Smithfield, NSW
Dian Dao		Sydney Inorganics, Smithfield, NSW
Edwandy Fadjar	Organic Coordinator	Sydney Organics, Smithfield, NSW
Lana Nguyen	Senior LCMS Chemist	Sydney Organics, Smithfield, NSW
Somlok Chai	Microbiologist	Sydney Microbiology, Smithfield, NSW



General Comments

The analytical procedures used by the Environmental Division have been developed from established internationally recognized procedures such as those published by the USEPA, APHA, AS and NEPM. In house developed procedures are employed in the absence of documented standards or by client request.

Where moisture determination has been performed, results are reported on a dry weight basis.

Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

When sampling time information is not provided by the client, sampling dates are shown without a time component. In these instances, the time component has been assumed by the laboratory for processing purposes.

Where a result is required to meet compliance limits the associated uncertainty must be considered. Refer to the ALS Contact for details.

Key : CAS Number = CAS registry number from database maintained by Chemical Abstracts Services. The Chemical Abstracts Service is a division of the American Chemical Society.
LOR = Limit of reporting
^ = This result is computed from individual analyte detections at or above the level of reporting
ø = ALS is not NATA accredited for these tests.
~ = Indicates an estimated value.

- EP202: Poor matrix spike recovery for due to matrix interferences(confirmed by re-analysis).
- Sampling time not provided. For operational reasons an assumed date/time (3pm on date of receipt) is used. Sample results may be affected if the analysis falls outside of actual holding time.
- MF = membrane filtration
- CFU = colony forming unit
- Membrane filtration (MF) results for MW006 and MW023 are reported as an estimate (~) when the growth of bacteria on the filter membrane is counted <10cfu and/or >100cfu.
- MW023 is ALS's internal code and is equivalent to AS4276.9.
- MW006 is ALS's internal code and is equivalent to AS4276.7.



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)		Client sample ID		COOLING TOWER	----	----	----	----
Client sampling date / time		[18-Aug-2016]		----	----	----	----	----
Compound	CAS Number	LOR	Unit	ES1618232-001	-----	-----	-----	-----
				Result	----	----	----	----
EA005: pH								
pH Value	----	0.01	pH Unit	8.18	----	----	----	----
EA010P: Conductivity by PC Titrator								
Electrical Conductivity @ 25°C	----	1	µS/cm	1550	----	----	----	----
ED037P: Alkalinity by PC Titrator								
Hydroxide Alkalinity as CaCO3	DMO-210-001	1	mg/L	<1	----	----	----	----
Carbonate Alkalinity as CaCO3	3812-32-6	1	mg/L	<1	----	----	----	----
Bicarbonate Alkalinity as CaCO3	71-52-3	1	mg/L	97	----	----	----	----
Total Alkalinity as CaCO3	----	1	mg/L	97	----	----	----	----
ED045G: Chloride by Discrete Analyser								
Chloride	16887-00-6	1	mg/L	307	----	----	----	----
ED093F: Dissolved Major Cations								
Sodium	7440-23-5	1	mg/L	177	----	----	----	----
ED093F: SAR and Hardness Calculations								
Total Hardness as CaCO3	----	1	mg/L	356	----	----	----	----
Sodium Adsorption Ratio	----	0.01	-	4.08	----	----	----	----
EG020F: Dissolved Metals by ICP-MS								
Aluminium	7429-90-5	0.01	mg/L	0.12	----	----	----	----
Arsenic	7440-38-2	0.001	mg/L	0.002	----	----	----	----
Beryllium	7440-41-7	0.001	mg/L	<0.001	----	----	----	----
Cadmium	7440-43-9	0.0001	mg/L	<0.0001	----	----	----	----
Cobalt	7440-48-4	0.001	mg/L	<0.001	----	----	----	----
Copper	7440-50-8	0.001	mg/L	0.120	----	----	----	----
Lead	7439-92-1	0.001	mg/L	<0.001	----	----	----	----
Lithium	7439-93-2	0.001	mg/L	0.005	----	----	----	----
Manganese	7439-96-5	0.001	mg/L	0.003	----	----	----	----
Molybdenum	7439-98-7	0.001	mg/L	<0.001	----	----	----	----
Nickel	7440-02-0	0.001	mg/L	0.012	----	----	----	----
Selenium	7782-49-2	0.01	mg/L	<0.01	----	----	----	----
Uranium	7440-61-1	0.001	mg/L	<0.001	----	----	----	----
Vanadium	7440-62-2	0.01	mg/L	<0.01	----	----	----	----
Zinc	7440-66-6	0.005	mg/L	0.012	----	----	----	----
Boron	7440-42-8	0.05	mg/L	0.18	----	----	----	----
Iron	7439-89-6	0.05	mg/L	0.15	----	----	----	----
EG035F: Dissolved Mercury by FIMS								



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID	COOLING TOWER	----	----	----	----
Client sampling date / time				[18-Aug-2016]	----	----	----	----	
Compound	CAS Number	LOR	Unit	ES1618232-001	-----	-----	-----	-----	
				Result	----	----	----	----	
EG035F: Dissolved Mercury by FIMS - Continued									
Mercury	7439-97-6	0.0001	mg/L	<0.0001	----	----	----	----	
EG050F: Dissolved Hexavalent Chromium									
Hexavalent Chromium	18540-29-9	0.01	mg/L	<0.01	----	----	----	----	
EK040P: Fluoride by PC Titrator									
Fluoride	16984-48-8	0.1	mg/L	3.5	----	----	----	----	
EK059G: Nitrite plus Nitrate as N (NOx) by Discrete Analyser									
Nitrite + Nitrate as N	----	0.01	mg/L	1.76	----	----	----	----	
EK061G: Total Kjeldahl Nitrogen By Discrete Analyser									
Total Kjeldahl Nitrogen as N	----	0.1	mg/L	2.0	----	----	----	----	
EK062G: Total Nitrogen as N (TKN + NOx) by Discrete Analyser									
^ Total Nitrogen as N	----	0.1	mg/L	3.8	----	----	----	----	
EK067G: Total Phosphorus as P by Discrete Analyser									
Total Phosphorus as P	----	0.01	mg/L	2.13	----	----	----	----	
EP068A: Organochlorine Pesticides (OC)									
alpha-BHC	319-84-6	0.5	µg/L	<0.5	----	----	----	----	
Hexachlorobenzene (HCB)	118-74-1	0.5	µg/L	<0.5	----	----	----	----	
beta-BHC	319-85-7	0.5	µg/L	<0.5	----	----	----	----	
gamma-BHC	58-89-9	0.5	µg/L	<0.5	----	----	----	----	
delta-BHC	319-86-8	0.5	µg/L	<0.5	----	----	----	----	
Heptachlor	76-44-8	0.5	µg/L	<0.5	----	----	----	----	
Aldrin	309-00-2	0.5	µg/L	<0.5	----	----	----	----	
Heptachlor epoxide	1024-57-3	0.5	µg/L	<0.5	----	----	----	----	
trans-Chlordane	5103-74-2	0.5	µg/L	<0.5	----	----	----	----	
alpha-Endosulfan	959-98-8	0.5	µg/L	<0.5	----	----	----	----	
cis-Chlordane	5103-71-9	0.5	µg/L	<0.5	----	----	----	----	
Dieldrin	60-57-1	0.5	µg/L	<0.5	----	----	----	----	
4,4`-DDE	72-55-9	0.5	µg/L	<0.5	----	----	----	----	
Endrin	72-20-8	0.5	µg/L	<0.5	----	----	----	----	
beta-Endosulfan	33213-65-9	0.5	µg/L	<0.5	----	----	----	----	
4,4`-DDD	72-54-8	0.5	µg/L	<0.5	----	----	----	----	
Endrin aldehyde	7421-93-4	0.5	µg/L	<0.5	----	----	----	----	
Endosulfan sulfate	1031-07-8	0.5	µg/L	<0.5	----	----	----	----	
4,4`-DDT	50-29-3	2	µg/L	<2.0	----	----	----	----	
Endrin ketone	53494-70-5	0.5	µg/L	<0.5	----	----	----	----	



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID	COOLING TOWER	----	----	----	----
Client sampling date / time				[18-Aug-2016]	----	----	----	----	
Compound	CAS Number	LOR	Unit	ES1618232-001	-----	-----	-----	-----	
				Result	----	----	----	----	
EP068A: Organochlorine Pesticides (OC) - Continued									
Methoxychlor	72-43-5	2	µg/L	<2.0	----	----	----	----	
^ Total Chlordane (sum)	----	0.5	µg/L	<0.5	----	----	----	----	
^ Sum of DDD + DDE + DDT	72-54-8/72-55-9/5 0-2	0.5	µg/L	<0.5	----	----	----	----	
^ Sum of Aldrin + Dieldrin	309-00-2/60-57-1	0.5	µg/L	<0.5	----	----	----	----	
EP068B: Organophosphorus Pesticides (OP)									
Dichlorvos	62-73-7	0.5	µg/L	<0.5	----	----	----	----	
Demeton-S-methyl	919-86-8	0.5	µg/L	<0.5	----	----	----	----	
Monocrotophos	6923-22-4	2	µg/L	<2.0	----	----	----	----	
Dimethoate	60-51-5	0.5	µg/L	<0.5	----	----	----	----	
Diazinon	333-41-5	0.5	µg/L	<0.5	----	----	----	----	
Chlorpyrifos-methyl	5598-13-0	0.5	µg/L	<0.5	----	----	----	----	
Parathion-methyl	298-00-0	2	µg/L	<2.0	----	----	----	----	
Malathion	121-75-5	0.5	µg/L	<0.5	----	----	----	----	
Fenthion	55-38-9	0.5	µg/L	<0.5	----	----	----	----	
Chlorpyrifos	2921-88-2	0.5	µg/L	<0.5	----	----	----	----	
Parathion	56-38-2	2	µg/L	<2.0	----	----	----	----	
Pirimphos-ethyl	23505-41-1	0.5	µg/L	<0.5	----	----	----	----	
Chlorfenvinphos	470-90-6	0.5	µg/L	<0.5	----	----	----	----	
Bromophos-ethyl	4824-78-6	0.5	µg/L	<0.5	----	----	----	----	
Fenamiphos	22224-92-6	0.5	µg/L	<0.5	----	----	----	----	
Prothiofos	34643-46-4	0.5	µg/L	<0.5	----	----	----	----	
Ethion	563-12-2	0.5	µg/L	<0.5	----	----	----	----	
Carbophenothion	786-19-6	0.5	µg/L	<0.5	----	----	----	----	
Azinphos Methyl	86-50-0	0.5	µg/L	<0.5	----	----	----	----	
EP202A: Phenoxyacetic Acid Herbicides by LCMS									
4-Chlorophenoxy acetic acid	122-88-3	10	µg/L	<10	----	----	----	----	
2,4-DB	94-82-6	10	µg/L	<10	----	----	----	----	
Dicamba	1918-00-9	10	µg/L	<10	----	----	----	----	
Mecoprop	93-65-2	10	µg/L	<10	----	----	----	----	
MCPA	94-74-6	10	µg/L	<10	----	----	----	----	
2,4-DP	120-36-5	10	µg/L	<10	----	----	----	----	
2,4-D	94-75-7	10	µg/L	<10	----	----	----	----	
Triclopyr	55335-06-3	10	µg/L	<10	----	----	----	----	
Silvex (2,4,5-TP/Fenoprop)	93-72-1	10	µg/L	<10	----	----	----	----	



Analytical Results

Sub-Matrix: WATER (Matrix: WATER)				Client sample ID	COOLING TOWER	----	----	----	----
Client sampling date / time				[18-Aug-2016]	----	----	----	----	
Compound	CAS Number	LOR	Unit	ES1618232-001	-----	-----	-----	-----	
				Result	----	----	----	----	
EP202A: Phenoxyacetic Acid Herbicides by LCMS - Continued									
2.4.5-T	93-76-5	10	µg/L	<10	----	----	----	----	
MCPB	94-81-5	10	µg/L	<10	----	----	----	----	
Picloram	1918-02-1	10	µg/L	<10	----	----	----	----	
Clopyralid	1702-17-6	10	µg/L	<10	----	----	----	----	
Fluroxypyr	69377-81-7	10	µg/L	<10	----	----	----	----	
2.6-D	575-90-6	10	µg/L	<10	----	----	----	----	
2.4.6-T	575-89-3	10	µg/L	<10	----	----	----	----	
MW006: Faecal Coliforms & E.coli by MF									
Faecal Coliforms	----	1	CFU/100mL	~1	----	----	----	----	
MW023: Enterococci by Membrane Filtration									
Enterococci	----	1	CFU/100mL	~4	----	----	----	----	
EP068S: Organochlorine Pesticide Surrogate									
Dibromo-DDE	21655-73-2	0.5	%	94.8	----	----	----	----	
EP068T: Organophosphorus Pesticide Surrogate									
DEF	78-48-8	0.5	%	73.2	----	----	----	----	
EP202S: Phenoxyacetic Acid Herbicide Surrogate									
2.4-Dichlorophenyl Acetic Acid	19719-28-9	10	%	100	----	----	----	----	



Surrogate Control Limits

Sub-Matrix: WATER		Recovery Limits (%)	
Compound	CAS Number	Low	High
EP068S: Organochlorine Pesticide Surrogate			
Dibromo-DDE	21655-73-2	30	120
EP068T: Organophosphorus Pesticide Surrogate			
DEF	78-48-8	27	129
EP202S: Phenoxyacetic Acid Herbicide Surrogate			
2,4-Dichlorophenyl Acetic Acid	19719-28-9	64	140

Appendix B – Sampling Field Notes



WASTE WATER SAMPLING FORM

Client Name: BOC Limited Kooragang Island

Date 18 8 2016 Time: 11:00
Day Month Year

Reasons for sampling: Research the possibility of using cooling tower wastewater for irrigation

Location of sampling point: Near cooling towers, close to Egret St

Nature of sampling point Groundwater Tradewaste sump Surface water

Stormwater Other Please specify

Wastewater stored in 10,000 L Poly Tanks

Sample ID: Cooling Tower

Depth sample taken: 1 m

Sample appearance Clear

Water Level in Tank 1.2 m

Volume of sample taken 1.5 L

Name of Sampler AB

Method of sampling In-situ bailer

Nature of sample point Storage Tank

COC Reference No. AB180816

Number of Bottles 7

Other comments:

NOTE: ONE WATER SAMPLING FORM TO BE COMPLETED FOR EACH SAMPLE POINT